

**Town of New Windsor
Butterhill Well GAC PFAS Clearance Sampling Results**

| Date | Analyte | Result¹ Raw Water (BHPRE) | Result Post-Treatment (BHTRAIN1POST) | Result Post-Treatment (BHTRAIN2POST) | Result Post-Treatment (BHTRAIN3POST) | Comparison Value (MCL³ or Guidance Value) |
|--------------|----------------|---|---|---|---|---|
| October 2019 | PFOA | 3.5 | ND ² | ND | ND | 70 ⁴ |
| | PFOS | 3.1 | ND | ND | ND | 70 ⁴ |
| | PFOA+PFOS | 6.6 | ND | ND | ND | 70 ⁴ |

Notes:

1. PFOS and PFOA results and comparison values are reported in parts per trillion (ppt, nanograms per liter, ng/l).
2. "ND" means non-detect. The analyte was not detected in the sample.
3. MCL (Maximum Contaminant Level, mg/l) is the maximum permissible level of a contaminant in water delivered by a public water system.
4. Guidance: USEPA Public Health Advisory for drinking water is currently 70 ppt.