



TOWN OF NEW WINDSOR

WATER DEPARTMENT

555 Union Avenue

New Windsor, NY 12553

phone: (845) 561-2550 fax: (845)565-0626

e-mail: nwwater@hvc.rr.com

ITEMS REQUIRED FOR METER PIT

1. PRE-CAST OR BUILT IN-PLACE VAULT
 - a. Minimum size: 6'6" x 12'0"
 - b. All penetrations sleeved for 'Link-Seal' caulking.
 - c. Sump pit cast or penetration for 'to open' drain.
2. ACCESS HATCH: To be determined by Engineer or Contractor.
3. METER: SENSUS WITH RADIO READ
4. VALVES
 - a. 4" to 12" MUELLER, A-2360 Series, resilient wedge, M.J., 'NO EQUAL'
 - b. 16" and up MUELLER, A-3211 Series, Linesal III Butterfly, M.J., 'NO EQUAL'