

For the purposes of interpreting the test values shown in the following laboratory results, please see the example below:

For example, in the test results for the sample taken from the Butter Hill WFP Entry Point on 9/27/18 and reported on 10/9/2018 (which results were subsequently provided by NYSDOH to the Town, in writing, on 4/4/19), the reported value of <2.00 ng/l for PFOA means the lab was able to test for this substance down to that level and found no traces of PFOA in this sample of the water.

May 25, 2016

PW 1  
PW 2

RECEIVED  
APR 30 2019

Ron Bayer  
EnviroTest Laboratories Inc.  
315 Fullerton Avenue  
Newburgh, NY 12550

Town of New Windsor Attorney's Office

RE: Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

Dear Ron Bayer:

Enclosed are the analytical results for sample(s) received by the laboratory on May 06, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current TNI standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Bo Garcia  
bo.garcia@pacelabs.com  
Project Manager

Enclosures

cc: Debra Bayer, EnviroTest Laboratories Inc.  
Renee Cusack, EnviroTest Laboratories Inc.  
Joyce Esposito, EnviroTest Laboratories Inc.  
Janine Rader, EnviroTest Laboratories Inc.  
Meredith Ruthven, EnviroTest Laboratories Inc.



### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

## CERTIFICATIONS

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

---

### Ormond Beach Certification IDs

8 East Tower Circle, Ormond Beach, FL 32174

Alabama Certification #: 41320

Connecticut Certification #: PH-0216

Delaware Certification: FL NELAC Reciprocity

Florida Certification #: E83079

Georgia Certification #: 955

Guam Certification: FL NELAC Reciprocity

Hawaii Certification: FL NELAC Reciprocity

Illinois Certification #: 200068

Indiana Certification: FL NELAC Reciprocity

Kansas Certification #: E-10383

Louisiana Certification #: FL NELAC Reciprocity

Louisiana Environmental Certificate #: 05007

Maryland Certification: #346

Michigan Certification #: 9911

Mississippi Certification: FL NELAC Reciprocity

Missouri Certification #: 236

Montana Certification #: Cert 0074

Nebraska Certification: NE-OS-28-14

Nevada Certification: FL NELAC Reciprocity

New York Certification #: 11608

North Carolina Environmental Certificate #: 667

North Carolina Certification #: 12710

North Dakota Certification #: R-216

Oklahoma Certification #: D9947

Pennsylvania Certification #: 68-00547

Puerto Rico Certification #: FL01264

South Carolina Certification: #96042001

Tennessee Certification #: TN02974

Texas Certification: FL NELAC Reciprocity

US Virgin Islands Certification: FL NELAC Reciprocity

Virginia Environmental Certification #: 460165

Wyoming Certification: FL NELAC Reciprocity

West Virginia Certification #: 9962C

Wisconsin Certification #: 399079670

Wyoming (EPA Region 8): FL NELAC Reciprocity

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

### SAMPLE SUMMARY

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

---

Lab ID	Sample ID	Matrix	Date Collected	Date Received
35243167001	PW 1	Water	05/05/16 14:40	05/06/16 11:20
35243167002	PW 2	Water	05/05/16 15:00	05/06/16 11:20

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

### SAMPLE ANALYTE COUNT

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35243167001	PW 1	EPA 537	WFH	8	PASI-O
35243167002	PW 2	EPA 537	WFH	8	PASI-O

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

### ANALYTICAL RESULTS

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

Sample: PW 1 Lab ID: 35243167001 Collected: 05/05/16 14:40 Received: 05/06/16 11:20 Matrix: Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
<b>537 Perfluorinated Compounds</b>		Analytical Method: EPA 537 Preparation Method: EPA 537							
Perfluorobutanesulfonic acid	<0.030	ug/L	0.090	0.030	1	05/17/16 22:45	05/23/16 20:32	375-73-5	
Perfluoroheptanoic acid	<0.0033	ug/L	0.010	0.0033	1	05/17/16 22:45	05/23/16 20:32	375-85-9	
Perfluorohexanesulfonic acid	<0.010	ug/L	0.030	0.010	1	05/17/16 22:45	05/23/16 20:32	355-46-4	
Perfluorononanoic acid	<0.00067	ug/L	0.020	0.00067	1	05/17/16 22:45	05/23/16 20:32	375-95-1	
5 Perfluorooctanesulfonic acid	<0.0013	ug/L	<1.3	0.040	0.0013	1	05/17/16 22:45	05/23/16 20:32	1763-23-1
14 Perfluorooctanoic acid	<0.00067	ug/L	<0.67	0.020	0.00067	1	05/17/16 22:45	05/23/16 20:32	335-67-1
<b>Surrogates</b>									
Perfluorohexanoic acid (S)	88	%	70-130		1	05/17/16 22:45	05/23/16 20:32		
Perfluorodecanoic acid (S)	91	%	70-130		1	05/17/16 22:45	05/23/16 20:32		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

### ANALYTICAL RESULTS

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

Sample: PW 2 Lab ID: 35243167002 Collected: 05/05/16 15:00 Received: 05/06/16 11:20 Matrix: Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
<b>537 Perfluorinated Compounds</b>		Analytical Method: EPA 537 Preparation Method: EPA 537							
Perfluorobutanesulfonic acid	<0.030	ug/L	0.090	0.030	1	05/17/16 22:45	05/23/16 21:10	375-73-5	
Perfluoroheptanoic acid	<0.0033	ug/L	0.010	0.0033	1	05/17/16 22:45	05/23/16 21:10	375-85-9	
Perfluorohexanesulfonic acid	<0.010	ug/L	0.030	0.010	1	05/17/16 22:45	05/23/16 21:10	355-46-4	
Perfluorononanoic acid	<0.00067	ug/L	0.020	0.00067	1	05/17/16 22:45	05/23/16 21:10	375-95-1	
Perfluorooctanesulfonic acid	<0.0013	ug/L	0.040	0.0013	1	05/17/16 22:45	05/23/16 21:10	1763-23-1	
Perfluorooctanoic acid	<0.00067	ug/L	0.020	0.00067	1	05/17/16 22:45	05/23/16 21:10	335-67-1	
<b>Surrogates</b>									
Perfluorohexanoic acid (S)	113	%	70-130		1	05/17/16 22:45	05/23/16 21:10		
Perfluorodecanoic acid (S)	89	%	70-130		1	05/17/16 22:45	05/23/16 21:10		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

### QUALITY CONTROL DATA

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

QC Batch: OEXT/28130 Analysis Method: EPA 537  
QC Batch Method: EPA 537 Analysis Description: 537 Perfluorinated Compounds  
Associated Lab Samples: 35243167001, 35243167002

METHOD BLANK: 1575709 Matrix: Water  
Associated Lab Samples: 35243167001, 35243167002

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Perfluorobutanesulfonic acid	ug/L	<0.030	0.090	0.030	05/23/16 19:16	
Perfluoroheptanoic acid	ug/L	<0.0033	0.010	0.0033	05/23/16 19:16	
Perfluorohexanesulfonic acid	ug/L	<0.010	0.030	0.010	05/23/16 19:16	
Perfluorononanoic acid	ug/L	<0.00067	0.020	0.00067	05/23/16 19:16	
Perfluorooctanesulfonic acid	ug/L	<0.0013	0.040	0.0013	05/23/16 19:16	
Perfluorooctanoic acid	ug/L	<0.00067	0.020	0.00067	05/23/16 19:16	
Perfluorodecanoic acid (S)	%	82	70-130		05/23/16 19:16	
Perfluorohexanoic acid (S)	%	77	70-130		05/23/16 19:16	

LABORATORY CONTROL SAMPLE: 1575710

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Perfluorobutanesulfonic acid	ug/L	.09	0.10	116	50-150	
Perfluoroheptanoic acid	ug/L	.01	0.010	102	50-150	
Perfluorohexanesulfonic acid	ug/L	.03	0.030J	99	50-150	
Perfluorononanoic acid	ug/L	.02	0.023	116	50-150	
Perfluorooctanesulfonic acid	ug/L	.04	0.038J	96	50-150	
Perfluorooctanoic acid	ug/L	.02	0.022	110	50-150	
Perfluorodecanoic acid (S)	%			92	70-130	
Perfluorohexanoic acid (S)	%			92	70-130	

LABORATORY CONTROL SAMPLE & LCSD: 1576541

Parameter	Units	Spike Conc.	LCS Result	1576542		% Rec Limits	RPD	Max RPD	Qualifiers
				LCSD Result	% Rec				
Perfluorobutanesulfonic acid	ug/L	.36	0.37	0.43	102	119	15	20	
Perfluoroheptanoic acid	ug/L	.04	0.039	0.045	98	112	13	20	
Perfluorohexanesulfonic acid	ug/L	.12	0.12	0.12	98	100	2	20	
Perfluorononanoic acid	ug/L	.08	0.078	0.10	97	126	26	20	R1
Perfluorooctanesulfonic acid	ug/L	.16	0.15	0.16	95	100	5	20	
Perfluorooctanoic acid	ug/L	.08	0.080	0.094	99	117	17	20	
Perfluorodecanoic acid (S)	%				99	103			
Perfluorohexanoic acid (S)	%				94	92			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..



## QUALIFIERS

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.  
ND - Not Detected at or above adjusted reporting limit.  
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.  
MDL - Adjusted Method Detection Limit.  
PQL - Practical Quantitation Limit.  
RL - Reporting Limit.  
S - Surrogate  
1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.  
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.  
LCS(D) - Laboratory Control Sample (Duplicate)  
MS(D) - Matrix Spike (Duplicate)  
DUP - Sample Duplicate  
RPD - Relative Percent Difference  
NC - Not Calculable.  
SG - Silica Gel - Clean-Up  
U - Indicates the compound was analyzed for, but not detected.  
N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.  
Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.  
TNI - The NELAC Institute.

### LABORATORIES

PASI-O Pace Analytical Services - Ormond Beach

### ANALYTE QUALIFIERS

R1 RPD value was outside control limits.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Town of New Windsor Water Syst  
Pace Project No.: 35243167

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35243167001	PW 1	EPA 537	OEXT/28130	EPA 537	GCSV/18350
35243167002	PW 2	EPA 537	OEXT/28130	EPA 537	GCSV/18350

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, Inc..



**Sample Condition Upon Receipt Form (SCUR)**

**NO#: 35243167**

PI **PM: VEG Due Date: 05/20/16**  
**CLIENT: EVNTES**

Date and Initials of person examining contents: 5/6/16 1120  
Label: \_\_\_\_\_  
Deliver: 6206  
pH: \_\_\_\_\_

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace Other  \_\_\_\_\_  
Shipping Method:  First Overnight  Priority Overnight  Standard Overnight  Ground  
Billing:  Recipient  Sender  Third Party  Unknown Cooler Size if Applicable: \_\_\_\_\_  
Tracking # 776277146288

Custody Seal on Cooler/Box Present:  yes  no Seals intact:  yes  no  
Packing Material:  Bubble Wrap  Bubble Bags  None  Other \_\_\_\_\_ Biological Tissue is Frozen: Yes No N/A  
Thermometer Used T-221 Type of Ice:  Blue  None  Samples on ice, cooling process has begun  
Cooler #1 Temperature°C 2.2 (Visual) 0 (Correction Factor) 2.2 (Actual)  
Cooler #2 Temperature°C \_\_\_\_\_ (Visual) \_\_\_\_\_ (Correction Factor) \_\_\_\_\_ (Actual)  
Cooler #3 Temperature°C \_\_\_\_\_ (Visual) \_\_\_\_\_ (Correction Factor) \_\_\_\_\_ (Actual) Temp should be above freezing to 6°C  
Cooler #4 Temperature°C \_\_\_\_\_ (Visual) \_\_\_\_\_ (Correction Factor) \_\_\_\_\_ (Actual)  
Cooler #5 Temperature°C \_\_\_\_\_ (Visual) \_\_\_\_\_ (Correction Factor) \_\_\_\_\_ (Actual)  
Cooler #6 Temperature°C \_\_\_\_\_ (Visual) \_\_\_\_\_ (Correction Factor) \_\_\_\_\_ (Actual)

**Comments:**

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature & Sampler Name COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Pace Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	HNO3 pH<2 HCl pH<2
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: VOA, Coliform, TOC, O&G	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	H2SO4 pH<2 NaOH pH>12 NaOH/ZnOAc pH>9
No Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

**Client Notification/ Resolution:**

Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Comments/ Resolution (use back for additional comments): \_\_\_\_\_

Project Manager Review: \_\_\_\_\_ Date: \_\_\_\_\_